

DRINKING WATER PROBLEM CORRECTED

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

As a customer of Oakmont Water Authority, you were notified on 9/23/21 of a problem with our drinking water and were advised to not drink the water without boiling it first. We are pleased to report that the problem has been corrected and that it is no longer necessary to boil your water before use. We apologize for any inconvenience and thank you for your patience.

What happened? What was done?

Oakmont Water Authority did not adequately protect one of its facility's covered reservoirs. Evidence of this violation was confirmed by the presence of a small mouse within the covered reservoir. Oakmont Water Authority flushed the affected system thoroughly to re-establish disinfectant residuals. Once this was completed late Sunday evening, multiple rounds of Chlorine and Bacteria samples were taken with redundancy to ensure the water was and is safe to drink again.

As always, you may contact:

Oakmont Water Authority
721 Allegheny Avenue
Oakmont, PA 15139
412-828-3388

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Oakmont Water Authority.

PWS ID#: 5020036

Date distributed: 9/29/21